




CONNECTION EVALUATION

Keystone Unit:	Country Manor	
Manufacturer:	Synteen	
Geogrid Type:	SF 35	
Laboratory:	BCGT	8/5/2002

Peak Connection Equation Fit

	English	Metric
Intercept (plf)	403	5.88
Slope1	36.1	36.1
Break - Normal	730	10.65
Slope2	13.7	13.7
Maximum (plf)	1153	16.83

3/4" Serviceability Equation Fit

Intercept (plf)	293	4.28
Slope1	25.0	25.0
Break - Normal	930	13.57
Slope2	14.0	14.0
Maximum (plf)	900	13.13

Laboratory Test Data

[illegible]